



AMENDMENT NO.1 TO SOLICITATION

TO: ALL VENDORS

FROM: Angie DeVeaux, Procurement Manager I

SUBJECT: SOLICITATION NUMBER: **Q201119ADD, Painting of Fire Protection Piping in the MUSC President Street Garage**

DATE: December 18, 2019

Amendment No. 1- Question and Answer.

Question:

The solicitation states that all work is to be completed between 7PM and 5AM. This should not affect cleaning but it may be difficult to maintain proper painting conditions (surface temp, air temp, humidity) at night. Would it be possible to complete painting during the day?

Answer:

The painting may be completed during the day, but the timing of the work must be coordinated with the Office of Parking Management Facilities Manager so spaces can be blocked and traffic can be controlled in the areas where the pipe runs across the roadway. All cleaning must be done at night.

Authorized Signature

Name of Offeror

Date